

Message

From: Pocsik Mark [mpocsik@facil.umass.edu]
Sent: 5/10/2011 4:34:25 PM
To: Lobik Stephen [slobik@facil.umass.edu]; Roger Jarosz [rjarosz@ingledc.com]
CC: Salem, Sharon (DPH) [/O=COMMONWEALTH OF MASSACHUSETTS/OU=MassMail-01/cn=Recipients/cn=Sharon.Salem]; Hanchett, James (DPH) [/O=COMMONWEALTH OF MASSACHUSETTS/OU=MassMail-01/cn=Recipients/cn=James.Hanchett]; Kevin Riordon [kevinr@dietzarch.com]
Subject: RE: DPH Room 251

Steve,

It's the old door in the corridor to N251.

Mark

Mark S. Pocsik

Construction Engineer

Facilities Planning

University of Massachusetts

360 Campus Center Way

Amherst, Ma. 01003-9248

Office: 413-577-1713

Cell: [REDACTED]

Fax: 413-545-3684

From: Lobik Stephen
Sent: Tuesday, May 10, 2011 8:57 AM
To: Roger Jarosz
Cc: Pocsik Mark; 'Salem, Sharon (DPH)'; Hanchett, James (DPH); Kevin Riordon
Subject: DPH Room 251

Roger,

There are still a few items that need to be completed. Door silencers need to be installed on the new doors. Not all of them have them. Also there is ceiling grid that is damaged that needs to be replaced and lastly. RDK told Adams they need to replace the belt on the AHU above the ceiling. I don't believe that work has been completed. Please get back to me with a schedule to complete this work.

Thanks,

Stephen

Stephen Lobik

Capital Project Manager

Facilities Planning Division

University of Massachusetts

(T) 413-545-6516

(C) [REDACTED]

(F) 413-545-3684

slobik@facil.umass.edu